

TOWN of MONROVIA  
ORDINANCE NO. 04-2019

AMENDMENT TO THE SUBDIVISION CONTROL ORDINANCE 2004-04

Ordinance 2004-04, adopted September 28, 2004, establishing the Subdivision Control Ordinance, a set of rules and regulations, is hereby amended by replacing Chapter 6, 6.3 with the following language:

6.3 FIRE HYDRANTS

Fire Hydrants shall be required for all subdivisions except those having lots served by individual wells. No water lines shall be placed that are smaller than 6 inches in diameter, and where necessary, 8 inches shall be required. All water supply lines shall be sufficient to provide a flow rate of water capable of providing fire protection. Fire hydrants shall be required for all new development where the parcel of land is divided into more than two housing sites and their locations shall be approved by the fire department. If a building site has no access to piped water, the fire protection level shall meet the state standards.

PASSED AND ADOPTED by the Town Council of the Town of Monrovia, Indiana this 25th day of November, 2019.

Robert L. Marley, Robert L. Marley, President  
Philip Fowler, Philip Fowler, Vice President  
Loren Moore, Loren Moore, Member  
Bonnie Silsby-Inman, Bonnie Silsby-Inman, Member  
Carol Youngblood, Carol Youngblood, Member

ATTEST: Danny Chenault, Danny Chenault, Clerk-Treasurer of Monrovia